

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2019/NDZ/ 1388

Dated: 8/7/19

FIRE SAFETY CERTIFICATE

Certified that the My Fairy Land Public School C-141/A, Street No.4, New Usmanpur, 1<sup>st</sup> Pusta, Delhi-53, comprised of ground plus one upper floor was issued NOC vide Letter no. F6/DFS/MS/School/2016/NDZ/617 dated 21/04/19. The school building was inspected by the officer concerned of this department on 02/07/19 in the presence of Sh. Satish Chand (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular no. 262-362 Dated 17/01/2005 and the school building is fit for occupancy class "B" 'Educational Building' with effect from 8.7.19... for a period of **three** years, subject to conditions, printed overleaf.

Issued on 8.7.19 at New Delhi by

(Sunil Chawdhary)  
Dy.Chief Fire Officer

To,

The Manager,  
My Fairy Land Public School  
C-141/A, Street No.4, New Usmanpur, 1<sup>st</sup> Pusta, Delhi-53.

Copy to:-

The Director of Education,  
East Delhi Municipal Corporation,  
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

