

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2019/ 1422

Dated: 11/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Aashraye** Guest House situated at Plot No-10/5, Nehru Enclave, Kalkaji Extn., New Delhi-110019, comprised of basement ground plus three upper floors was issued FSC by this department vide letter No. F.6/MS/DFS/GH/2016/SZ/957 dated 08/06/2016. The premises was re-inspected by officer concerned of this department on 18/06/2019 in the presence of Mr. Rahul (Manager) of the guest house and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for (**Ground Floor: 04 Guest Rooms, 1<sup>st</sup> Floor: 05 Guest Rooms, 2<sup>nd</sup> Floor: 05 Guest Rooms & 3<sup>rd</sup> Floor: 04 Guest Rooms, Total 18 Guest Rooms**) occupancy class "**Residential, Group-A**" (Lodging & Rooming House only) with effect from 11/07/2019 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 11/07/19 at New Delhi by

(Rajesh Panwar)  
Dy. Chief Fire Officer  
Ph: 011-26189168

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-110049
2. Proprietor, M/s **Aashraye** Guest House situated at Plot No-10/5, Nehru Enclave, Kalkaji Extn., New Delhi-110019

**Conditions for the validity of Fire Safety Certificate:**

1. **This FSC shall stand null & void without further communication after three months from the date of issue, if the requirements as stipulated in Gazette Notification No. F.5 (189)/AD/LB/2016/4053-67 dated 25/05/2019 is not implemented under intimation to Delhi Fire Service.**
2. The Basement shall be used strictly in accordance with provisions of Building Bye-Laws.
3. All the means of escape/entry/exit shall be kept free from any obstruction.
4. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life, property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire fighting system.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

