

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH/2019/WZ/ 1432

Dated: 12/07/2019

FIRE SAFETY CERTIFICATE

Certified that the Aman Deluxe located at A-30, Vishal Enclave, Rajouri Garden, New Delhi comprised of Basement , Ground Floor and 3 Upper Floors only owned / occupied by Aman Deluxe, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/GH/2016/WZ/692 Dated 02/05/2016. The premises was re-inspected by the officer concerned of Fire Service on 22.06.2019 in the presence of Mr. Baldev Singh (Proprietor) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for occupancy class "Residential" (Guest House) / Group 'A' with effect from 12/07/2019 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 12/07/19 at New Delhi.

(DHARAMPAL BHARDWAJ)
DEPUTYCHIEF FIRE OFFICER

Copy to :-

1. Joint Commissioner of Police(Lic.) Ist Floor, P .S.: Defense Colony New Delhi-110049 w.r.t. L No. 2080/Joint CP/Lic.(H)/Dated 14/03/2019

1. Mr. Baldev Singh, Aman Deluxe , A-30, Vishal Enclave, Rajouri Garden, New Delhi-27.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to Non Functional fire safety measure shall be at the responsibility of the management.
3. The trained Fire Fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The Basement shall be used strictly as per the provision of Building Bye- Laws.
6. **No temporary structure on terrace/ roof will be allowed.**
7. **"The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".**
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
9. **Smoke detectors with alarm system should be installed in entire Building within 3 months of issue of this NOC under intimation to this deptt**
10. **Fire Door Of minimum 1 hour capacity must be installed at the entrance of staircases at each floor where occupants are more than 10 on each floor.**

