

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/GH/2019/NDZ/ 1437

Dated: 12/07/19

FIRE SAFETY CERTIFICATE

Certified that the **M/s Ashirwad Inn Guest House**, located at **70-71, Church Mission Road, Fatehpuri, Delhi - 110006** comprised of Ground + three upper floors, Ground floor (reception + school), 1st floor (school) 2nd floor (trust office), 3rd floor (11 guest rooms), total 11 guest rooms was granted FSC by this department vide letter No.F6/DFS/MS/GH/2016/NDZ/1095 dated 30/06/16. The premise was re-inspected by the officer concerned of this department on 02/07/19 in the presence of **Sh. Sanjeev Soni (Proprietor)** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Guest House for 11 guest rooms only** with effect from 12/07/19 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued: - 12/07/19 at New Delhi by.


(Sunil Chawdhary)
Dy.Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi
2. Sh. (Manager),

✓ M/s Ashirwad Inn Guest House, 70-71, Church Mission Road, Fatehpuri, Delhi - 110006

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior is prohibited.
10. The Owner/occupier shall have to provide carbon-Monoxide detectors and Fire doors having fire resistance rating of not less than 01 hour at the entrance of staircase at each floor level, with in 03 months from the issuance date of this certificate.

