

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / 22/1464

Dated: 17/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the **Atlantis Park Ballroom Banquet LLP** located at **B-21, GF & FF & SF, GTK Road Industrial Area, Delhi-110033** comprised of **Ground, Mezzanine-I, First floors, Mezzanine-II & Second floor only** owned/ occupied by **Atlantis Park Ballroom Banquet LLP** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 08.07.2019 in the presence of **Sh Vishal Bhutani** and that the building/ premise is fit for occupancy Class Group-D Assembly with effect from 17/07/19 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on ....17/07/19... at New Delhi by

(Atul Garg)

Chief Fire Officer  
Ph-011-23414250

Copy to:-

1. The Dy. Health Officer, Civil Line Zone, 16, Rajpura Road, Delhi-110054.
2. M/s Atlantis Park Ballroom Banquet LLP located at B-21, GF & FF & SF, GTK Road Industrial Area, Delhi-110033.

### INSPECTION REPORT

- 1 Name & address of the building : Atlantis Park Ballroom Banquet LLP, B-21, GF & FF & SF, GTK Road  
Industrial Area, Delhi-110033.
- 2 Type of Occupancy : Assembly ( GF+ Mezz-I + FF+Mezz- II & SF only )
- 3 Type of Case : New Case
- 4 Details of previous NOC : Nil
- 5 Fire Safety directives letter No : F.6/DFS/MS/2019/168 dated : 02.05.2019
- 6 Date of inspection :08.07.2019
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers  
from the building side : Mr. Vishal Bhutani
9. Year of Construction : 2018
10. Applicant's letter No. : Nil dated 02.05.2019

Total plot area— 885.50 sqm.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	18m (approx)	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	2 m each & Mezz-II- 2m & 1.50m	2m each & Mezz-II- 2m & 1.50m	MR
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	2.0m x02	Provided	MR	

