

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / School/2019 / 1459

Dated: 16/7/2019

FIRE SAFETY CERTIFICATE

Certified that the **M.C.D Primary Girls School** located at **Narela Colony-01, Narela, Delhi-110040** comprised of **Ground and 01 upper floor** owned/occupied by **M.C.D Primary Girls School** was granted FSC by this department vide letter no. **F6/DFS/MS/2013/43** dated **06.03.2013** The premises was re-inspected by the officer concerned of this department on **18.06.2019** in presence of **Sh. Devki Singh (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from **16/7/19**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on **16/7/19**..... at New Delhi


(Dharampal Bhardwaj)

Dy. Chief Fire Officer

Ph.-011-25104544

Out

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, M.C.D Primary Girls School, Narela Colony-01, Narela, Delhi-110040.

INSPECTION REPORT

1. Name & address of the building : M.C.D Primary Girls School, Narela Colony-01, Narela, Delhi-110040.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (G+1 upper Floors)
4. Details of previous NOC : F6/DFS/MS/2013/43 dated: 06.03.2013
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 18.06.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Devki Singh (Principal)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated:15.05.2019

Plot Area-5343 m2

Covered Area:750 m2

No. of Class Room-14nos

No. of Student-252nos

| | Minimum Standards on fire prevention and fire safety U/R 33 | Circular of Director of Education | Provided at site | Remarks MR/NMR |
|-------------------|---|-----------------------------------|-------------------|----------------|
| 1 | Access to building | 6m | 6m | MR |
| | • Road width | 4.5m | 3.8m | MR(old case) |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | | | |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | 02 | 02 | MR |
| | • Upper Floors | NA | NA | NA |
| | • Basements | | | |
| | b. Width of staircases | 1.50M | 2.33m & 2.17m | MR |
| | • Upper Floors | NA | NA | NA |
| | • Basements | | | |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 1.5m | 1.7m | MR |
| | e. Width of Corridor | 1 m | 1.10m double door | MR |
| | f. Door Size | | | |
| | 3 | Compartmentation. | | |
| • Fire check door | | NA | NA | NA |

