

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / 1487

Dated: 19/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C Primary Boys/Girls School** located at **Ibrahimpur-II, Delhi-110036** comprised of **Ground + 01 upper floor** owned/occupied by **M.C Primary Boys/Girls School** have complied with the fire prevention and fire safety requirement in accordance with Director of Education vide letter no. 3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 18.06.2019 in presence of **Smt. Hemlata, Principal** and that the building/ premise is fit for occupancy class Group B Educational with effect from 14/07/2019..... for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules - 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 14/07/2019..... at New Delhi

  
(Atul Garg)  
Chief Fire Officer  
Ph.-011-23414250  


Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54
2. The Principal, M.C. Primary Boys/Girls School, Ibrahimpur-II, Delhi-110036.

INSPECTION REPORT

1. Name & address of the building : M.C Primary Boys /Girls School. Ibrahimpur, Delhi-110036.
2. Type of Occupancy : Educational
3. Type of Case : New Case (Ground + 01 upper floor)
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 18/06/2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Smt. Hemlata (Principal)
9. Year of Construction : 1999
10. Applicant's letter No. : Nil Dated-30.03.2019

Plot Area-3530.2sqm

Covered Area:2043.7sqm

No.of Class Room-11

No.of Student- 488

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.50m	1.52m & 1.70m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA

