

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1472

Dated: 18 / 07 / 2019


FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Pratibha School** located at **Vijay Nagar (New), Delhi-110009** comprised of **Ground floor only** owner/ occupied by **M.C. Pry. Pratibha School** was issued Fire Safety Certificate vide this office letter no. **No.F6/DFS/MS/2016/SCHOOL/WZ/983** dated **09.06.2016** The premises was re-inspected by the officer concerned of this department on **27.06.2019** in presence of **Smt. Paramjeet Kaur (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from**18/07/2019**... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

Issued on**18/07/2019**... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54
2. The Principal, M.C. Pry. Pratibha School, Vijay Nagar (New), Delhi-110009.

2/11

INSPECTION REPORT

1. Name & address of the building : M.C.Pry. Pratibha School, Vijay Nagar (New), Delhi-110009.
2. Type of Occupancy : Educational
3. Type of Case : Renewal, (Ground Floor- 04 shed)
4. Details of previous NOC : F6/DFS/MS/2016/School/WZ/983 dated 09.06.2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 27.06.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt Paramjeet Kaur (Principal)
9. Year of Construction : 1974
10. Applicant's letter No. : Nil Dated: 07.06.2019

Plot Area-3000 sq. m2

Covered Area:1729 sq.m2

No.of Class Room-14

No.of Student-300

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	05m	MR(old case)
	• Gate width	4.5m	1.75m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	NA	NA	NA	
	1 m	1m	MR	
3	Compartmentation.			

1

