

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1471

Dated: 18/07/2019

FIRE SAFETY CERTIFICATE

Certified that **M.C Primary School** located at **Ghanta Ghar, Delhi-110007** comprised of **Ground floor Only** owned/occupied by **M.C Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2016/SCHOOL/WZ/503** dated **01.04.2016** The premises was re-inspected by the officer concerned of this department on **27.06.2019** in presence of **Smt. Sunita Gupta (Teacher Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from 18/07/2019..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/07/2019..... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, M.C Primary School, Ghanta Ghar, Delhi-110007.

INSPECTION REPORT

1. Name & address of the building : M.C Primary School, Ghanta Ghar, Delhi-110007.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground floor only)
4. Details of previous NOC : F6/DFS/MS/2016/School/WZ/503 dated: 01.04.2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 27.06.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt. Sunita Gupta (Teacher Incharge)
9. Year of Construction : 1962
10. Applicant's letter No. : Nil Dated: 27.02.2019

Plot Area-331sq yard

Covered Area:235sq yard

No.of Class Room-04

No.of Student-164

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6m 4.5m NA	3.3m 1.5m NA	MR(old case) MR(old Case) NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3	Compartmentation.	1 m	1m	MR
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts 	NA NA	NA NA	NA NA

	<ul style="list-style-type: none"> Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	Basements	30 a/c per hour	NA	NA
	Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	Total numbers	02nos	03nos	MR
	Types	ABC/Co2	ABC-03	MR
	ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA

	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump			
	➤ Power Supply	NA	N/A	NA
	➤ Auto Starting of pump	NA	N/A	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	N/A	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

2115

19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.503 dated 01.04.2016.

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN

Dy. Commr

19/7/19

MS/Cell

ADO R/N. F.T

As approved, f.t. letter is put up for your signature OI

Dy. Commr

19/7/19

MS/Cell

16/4
12/7