

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1469

Dated 18/07/19

FIRE SAFETY CERTIFICATE

Certified that the **Pawa International** located at **Plot No-2, DDA Community Centre, Sector-14, Rohini, Delhi-110085** comprised of **02 Basement, Ground and 06 upper floors** owned/ occupied by **Pawan International** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2016/WZ/1067 dated 21.06.2016** The premises was re-inspected by the officers concerned of this department on **14.06.2019** in the presence of **Sh. Akhilesh (Manager)** and the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for occupancy **Mercantile/ Business & Assembly** with effect from 18/07/19 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on19/07/19... at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph-011-23414250
AG

Copy to:-

1. The Authorized Signatory, Pawa International Pvt. Ltd. Pawa Presidential Business, Park Tower-5, C-9, DDA Complex, Vasant Kunj, New Delhi-110070.

INSPECTION REPORT

1. Name & address of the building : Pawa International Pvt.Ltd, Plot No-2, DDA Community Centre, Sec-14, Rohini, Delhi-110085. (02 Basement+ Ground+06 Upper floor)
2. Type of Occupancy : Mixed (Mercantile/Business/Assemble)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2016/WZ/1067 dated : 21.06.2016
5. Fire Safety directives letter No : F6/DFS/MS/BP/2006/3488 Dated: 01/12/2006
6. Date of inspection :05.07.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Akhilesh (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated 14.05.2019

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/ NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15m	15m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	04	04	MR
	b. Width of staircases			
	• Upper Floors	Proposed as per plan 1.50 m	4x 1.50m	MR
	• Basements	As per BBL-1.25m Basement to Ground		
	c. Protection of exits			
	• Fire check door	Proposed as per plan 1.50 m	1.50 x 3 1.25m x 1	MR (As per BBL 1983)
	• Pressurization	As per BBL-1.25m		
	d. No. of continuous staircases to terrace			
	•	Required	Provided	MR
	e. Width of Corridor			
•	Required	Provided	MR	
f. Door Size				
•	02	02	MR	
•	2.4m	2.4m	MR	
•	1m	1m	MR	
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR

