

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / School/2019 / 1473

Dated: 18/07/2019


**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Co-ed Sr. Sec. School No-3** located at **Shakti Nagar, Delhi-110007**, comprised of **Ground and 03 upper floors** owned/ occupied by **Sarvodaya Co-ed Sr. Sec. School No-3**, was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/School/2016/WZ/1259 dated 10.08.2016** The premise was re-inspected by the officer concerned of this department on **27.06.2019** in the presence of **Sh. Ram Niwas Giri (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from ... **18/07/2019** ..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on ..... **18/07/2019** ..... at New Delhi

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, Sarvodaya Co-ed Sr. Sec. School No-3, Shakti Nagar, Delhi-07.

2/14

**INSPECTION REPORT**

- 1. Name & address of the building : Sarvodaya Co-ed Sr. Sec. School No-3, Shakti Nagar, Delhi-7
- 2. Type of Occupancy : Educational
- 3. Type of Case : Renewal 1 blocks (Ground plus 03 upper floors)
- 4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/1259 Dated: 10.08.2016
- 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/NBC Part-IV
- 6. Date of inspection : 27/06/2019
- 7. Name of the Inspecting Officers : ADO (RN)
- 8. Name and designation of officers from the building side : Mr. Ram Niwas Giri (Principal)
- 9. Year of Construction : 1968
- 10. Applicant's letter No. : SCOEDSSNO.3/SN/ dated: 29.05.2019

Plot Area-3 22sq m Covered Area:773 sq.m No of class rooms -22nos. No of students---700nos.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	2.1m & 1.5 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	02m	2.46m	MR
f. Door Size	1 m	1m	MR	
3	<b>Compartmentation.</b>			

K

