

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2019/SZ/ 1510

Dated:

23/07/19

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidhalaya, Mohan Garden New Delhi-110059 (ID-1618063) comprised of ground plus one upper floor owned/occupied by Delhi Government, have complied the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on 9.7.2019 in the presence of Mrs. Sita Viswerwaram (Vice Prencipal) and that the Premises/building is fit for occupancy class B "Educational building" with effect from....23/07/19 for a period of **three years** subject to conditions printed overleaf.

Issued on23/07/19..... at New Delhi by

(Atul Garg)

Chief Fire Officer

Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54.
2. Principal, Sarvodaya Kanya Vidhalaya, Mohan Garden New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

