

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2019/NDZ/ 1465

Dated: 17/07/2019

FIRE SAFETY CERTIFICATE

Certified that the Sharp Sight Centre, A-15, Swasthya Vihar, Vikas Marg Delhi-92, comprised of Basement ground plus two upper floors owned/occupied by Sharp Sight Centre was granted FSC vide letter no. F6/DFS/MS/2016/NDZ/893 Dated 30/05/16. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of this department on dated 04/07/19 in the presence of Mr. Vikas Kumar and that the building is fit for occupancy class C 'Institutional Building' with effect from17/7/19..... for a period of **three** years, subject to conditions printed overleaf.
Issued on.....17/07/19.....at New Delhi by


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

To,

Mr. Vikas Kumar,
Sharp Sight Centre A-15,
Swasthya Vihar, Vikas Marg Delhi-92.

Copy to-

The Directorate of Health Services
M.O. I/C Nursing Home Cell,
Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-32.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructi onal deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. Basement shall be used as per BBL.

