

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/WZ/2019/ 1530

Dated: 25/07/2019

FIRE SAFETY CERTIFICATE

Certified that the M/s Bikanervala Foods Pvt. Ltd. Ground & First Floor, Located at, Shop No-01, GF & 102,FF, B – 09, ITL Twin Tower, Netaji Subhash Place Pitampura New Delhi -110034 on Ground & First Floor of premises comprised of Basement+ Ground +10 upper Floors owned /occupied by M/s Bikanervala Foods Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 11/07/2019 in the presence of Sh Dipender Kumar Joshi (Manager) that the premises is fit for occupancy class “Assembly” Group D (Ground & First Floor)with effect from 25/7/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/7/19..... at New Delhi by.

(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Dy Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone Delhi.
2. M/s Bikanervala Foods Pvt. Ltd. Ground & First Floor, at, Shop No-01, GF & 102,FF, B – 09, ITL Twin Tower, Netaji Subhash Place Pitampura New Delhi -110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

