

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2019/ W2) 1534

Dated: 26/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the Aman Rex Pvt. Ltd. located at Plot No. G-8, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-41 comprised of Basement, Ground Floor, Mezzanine Floor and First Floor only owned / occupied by Aman Rex Pvt. Ltd., has already been issued Fire Safety Certificate vide letter No.F6/DFS/MS/2015/1464 dated 13.08.2015. The premises / Building was re-inspected by the officer concerned of Fire Service on 15.07.2019 in the presence of Sh. Subhash Arora (Director) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complies with Rule 33 of Delhi Fire Service, Rules 2010, and that the building / premises is fit for occupancy Industrial (Group-G) with effect from 26/07/2019 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 26/07/19 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Subhash Arora (Director), Aman Rex Pvt. Ltd. at Plot No. G-8, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-41.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

