

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2019/1551

Dated: 30/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the D. S. Memorial Public Sr. Sec. School at Extension, 2-C, Nangloi, Delhi-110041 comprised of Block I – Basement, Ground Floor, Two Uppers Floor, Block II-G+2 Upper Floors only owned / occupied by D. S. Memorial Public Sr. Sec. School, was earlier issued FSC by this department vide letter No. F6/DFS/MS/School/2016/WZ/938 dated 06/06/2016. The re-inspection was carried out by the officer from Fire Service on 15/07/2019 in the presence of Sh. Mahipal Yadav (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 / NBC (Part-IV) and that the building / premises is fit for occupancy class Educational (Group-B) with effect from 30/07/2019 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30/07/19 at New Delhi by.

  
(DHARAMPAL BHARDWAJ)  
DY. CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Mahipal Yadav (Manager), D.S. Memorial Public Sr. Sec. School, Extension, 2-C, Nangloi, Delhi-110041.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.
8. Basement shall be used as per the NBC (Part-IV) read with BBL 1983.
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

