

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ *School/wz/2019/1545*

Dated: *26/07/2019*

FIRE SAFETY CERTIFICATE

Certified that the Jesus Mary Joseph School located at G-17, Site-10, Paschim Vihar, New Delhi-110063 in a building comprised of Ground + Three Upper Floors only, owned / occupied by Jesus Mary Joseph School, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2016/WZ/861 dated 25/05/16. This premises was re-inspected by officers concerned of this department on 24/06/2019 in the presence of Mr. Mathew and found that the said building have deemed complied with the Fire prevention and Fire Safety requirements in accordance with Director of Education Circular No. F6/Estate/CC/Fire/Safety/ 2011/3298-3398 dated 01/03/2011/ NBC Part-IV and that the building / premises is fit for occupancy class Educational (Group-B) with effect from*26/07/19*..for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on *26/07/19* at New Delhi by.

26/07/19
(DHARAMPAL BHARDWAJ)
DY. CHIEF FIRE OFFICER.

AB 9c

Copy to :-

1. The Principal, Jesus Mary Joseph School, G-17, Site-10, Paschim Vihar, New Delhi-63.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the managemnt.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

INSPECTION REPORT

1. Name & address of the building: Jesus Mary Joseph School, G-17, Site-10, Paschim Vihar, New Delhi-110063.
2. Type of Occupancy : Educational (G. Floor & Three Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/861 dated 25/05/16
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/357 Dated 29/11/2013
6. Date of inspection : 24/06/2019
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)
8. Name and designation of Officer
from the building side : Mr. Mathew
9. Year of Construction : 2009-10 (Ground + 2), 2015-16 (3rd Floor added on existing G+2)
10. Applicant's letter No. : JMJS/D/2019-20/005 dated 25/05/2019

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dt. 01/03/2011 / NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	25 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	5	MR
	• Basements	NA	NA	NR
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.50 x 5 (up to 2 nd floor), 1.50 x 4 (up to 3 rd floor)	MR
	• Basements	NR	NR	NR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	4	4	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr	MR
	f. Door Size	1 Mtr (class room) 1.50 Mtr (Hall)	A) 1 mtr in each class rooms B) 2mtrx2 & 1.5x1 in hall	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	22	30	M/R
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	3 in each block	4	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	100mm	NR
	• Number of hydrants per floor	NR	2	NR
	• Hose Box	NR	2	NR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM & 180LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

B) Students are less than 45 in a single class room.

C) There is a hall on 3rd floor having three exits of width 2mtr x 2 & 1.50mtr x 1. Area of hall is 500m² approx.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2016/WZ/861 dated 25/05/16 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/(C/D)

[Handwritten signature]
15/7/19

[Handwritten signature]
15/7/19

[Handwritten signature]
15/7/19

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)