

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F-6/DFS/MS/Banq/2019/ 1537

Dated: 26/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Marina Dreams Banquet Hall ( A unit of Chintpurni Overseas Ltd.) Located at B-72/5, Ring Road, Wazirpur Ind. Area, Delhi- 110052, in a building comprised of Basement + Ground +2 Upper Floors owned/ occupied M/s Marina Dreams Banquet Hall ( A unit of Chintpurni Overseas Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 17/07/2019 in the presence of Sh. Luv Goel and found that the said building that the premises is fit for occupancy class " Assembly" Group D (Banquet at Ground, 1<sup>st</sup> Floor and & 2<sup>nd</sup> Floor) with effect from 26/7/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...26/07/19... at New Delhi by.

  
(Anil Garg)  
Chief Fire Officer  
Delhi Fire Service

- Copy to: 1. M/s Marina Dreams Banquet Hall ( A unit of Chintpurni Overseas Ltd.), B-72/5, Ring Road, Wazirpur Ind. Area, Delhi- 110052.  
2. The Dy Health Officer, A-1 Block, Keshav puram Zone, Public Health Department, Keshav Puram, Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The basement found being used as storage, it shall be strictly used as per BBL 1983.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Open set back area is not checked as it shall be checked by concerned building sanctioning authority.**
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

