

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / School/2019 / 1543

Dated: 26/07/2019


FIRE SAFETY CERTIFICATE

Certified that the M.C.D Boys/Girls School located at Mamarpur, Narela, Delhi-110040 comprised of **Ground and 01 upper floor** owned/occupied by M.C.D Boys/Girls School was granted FSC by this department vide letter no.F6/DFS/MS/SCHOOL/2016/WZ/1081 dated **28.06.2016** The premises was re-inspected by the officer concerned of this department on **11.06.2019** in presence of **Smt. Veena Sharma, Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from26/07/19..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on26/07/19..... at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, M.C.D Primary Boys/Girls School, Mamarpur, Narela, Delhi-110040.

N/10

INSPECTION REPORT

1. Name & address of the building : M.C.D Primary Boys/Girls School, Mamarpur, Narela, Delhi-110040.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (G+1 upper Floors)
4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/1081 dated: 28.06.2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 10.06.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mrs. Veena Sharma, Principal
9. Year of Construction : 2003
10. Applicant's letter No. : Nil Dated:16.05.2019

Plot Area-1176m² Covered Area:824 m² No. of Class Room-10 nos No. of Student-343 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	3.1m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50M	1.50m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	1 m	1.m	MR	

k

