

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / EM/ 1553

Dated: 30/07/2019

FIRE SAFETY CERTIFICATE

Certified that the M/s Pik Wik Restaurant, located at fourth floor 409, V3S Ring Road Mall, Plot no. 21, Sec.-3, Rohini, Manglam Place, Delhi-85 in the building comprised of **three basement, ground and eight upper floors** owned/ occupied by **Sh. Joginder Pal Singh** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2016/1150** dated **15.07.2016** The premises was re-inspected by the officers concerned of this department on **19.07.2019** in the presence of **Sh. Joginder Pal Singh (Proprietor)** of the Restaurant and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D(Assembly)** occupancy with effect from 30/07/19 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 30/07/19..... at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph-011-23414250

Copy to:-

1. Mr. Joginder Pal Singh, M/s Pik Wik Restaurant, fourth floor 409, V3S Ring Road Mall, Plot no. 21, Sec.-3, Rohini, Manglam Place, Delhi-110085.

INSPECTION REPORT

1. Name & address of the building : Pik Wik Restaurant, fourth floor 409, V3S Ring Road Mall, Plot no. 21
Sec.-3, Rohini, Manglam Place, Delhi-85. (Basement+ Ground + 08 Floor)
2. Type of Occupancy :Mixed Occupancy (Assembly/ Business)
3. Type of Case :Renewal
4. Details of previous NOC :F6/DFS/MS/2016/1150 dated 15.07.2016
5. Fire Safety directives letter No :NBC Part IV
6. Date of inspection :19/07/2019
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers
from the building side : Mr. Joginder Pal Singh (Proprietor)
9. Year of Construction :--
10. Applicant's letter No. : Nil dated : 04.07.2019

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	10m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	6m	6m	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	04for the Mall	04	MR
	b. Width of staircases			
	• Upper Floors	As per sanction plan	Provided	MR
	• Basements	As per sanction Plan	Provided	MR
	c. Protection of exits			
	• Fire check door			
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	For the Mall	For the Mall	MR
	e. Width of Corridor	01	01	MR