

C/25
DFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2019/1549

Dated: 30/07/19

FIRE SAFETY CERTIFICATE

Certified that **Vinci Public School** located at B-Block, 69 Patel Garden, Kakrola More, New Delhi- 110059 was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2006/3147 dated 20.10.2006 for ground plus one upper floor. The said school building was re-inspected by the officer concerned of this department on 11.07.2019 in the presence of Sh. Satyawan (Vice Principal) and found that the school management has constructed two more upper floors and now the school building is comprised of ground plus three upper floors and premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Services Rules, 2010 and that the building/premises is fit for occupancy class B "Educational Building", with effect from 30/07/19 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, printed overleaf.

Issued on 30/07/19 at New Delhi by.

Atul Garg
(Atul Garg)

Chief Fire Officer

Ph.: 011-23414250

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.
2. The Principal, Vinci Public School, B-Block, 69 Patel Garden, Kakrola More, New Delhi- 110059.

c/21

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

