

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1568

Dated 02/08/19

FIRE SAFETY CERTIFICATE

Certified that the **Cafeteria Block, Bhalswa Golf Course Facility Centre, Bhalswa, Delhi** comprised of **ground and first floor** owned/ occupied by **Delhi Development Authority** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **04.06.2019** in the presence of **Col. Rajender Dadhwal** and that the building/ premises is fit for occupancy "**Assembly**" at **ground & first floor** only with effect from 02/08/19 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on02/08/19..... at New Delhi by

(Atul Garg)
Chief Fire Officer
Ph-011-23414250

Copy to:-

1. The Dy. Director (Arch.), ---Ref:-DHO/CLZ/2015/277 dated 01.05.2015.
DDA, Sports Unit, HUPW, 8th floor, Vikas Minar, Delhi.
2. The Director, Cafeteria Block, Bhalswa Golf Course Facility Centre, Bhalswa, Delhi

INSPECTION REPORT

1. Name & address of the building : Cafeteria Block, Bhalswa Golf Course Facility Centre,
Bhalswa, Delhi.
2. Type of Occupancy : Assembly (Ground & first floor only)
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2017/80 dated 24.03.2017
6. Date of inspection : 04/06/2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Col. Rajender Dadhwal
9. Year of Construction : 2017-18
10. Applicant's letter No. : F.(13)/ACA-II (Sports)/HUPW/16/DDA/62 dated 07.05.2019.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2 m each	2 m each	MR(travelling distance meet)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2.0m	2m x 02	MR
3	Compartmentation.			

