

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/GH/NDZ/2019/ 1626

Dated : ~~14/8/19~~

**FIRE SAFETY CERTIFICATE**

Certified that the Alka Hotel located at 16/90, Connaught Place, New Delhi comprised of **Basement + Ground + Mezzanine + 03 Upper floors, Basement (Storage + Staff cafeteria + A.C. Plant), Ground floor (Reception + restaurant + kitchen), Mezzanine floor (02 guest rooms + office + restaurant & Bar), 1<sup>st</sup> floor to 2<sup>nd</sup> floor (07 guest rooms at each floor), 3<sup>rd</sup> floor (06 guest rooms) and terrace floor (boiler room + colling tower & water tank), total 22 guest rooms** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2016/NDZ/780 dated 17/05/16. The premises was re-inspected by the officer concerned of this department on 02/08/19 in the presence of **Sh. Ajay Aggrawal (CEO)** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, **Sub Division-A-1 as above 22 guest rooms only** with effect from ~~14/8/19~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~14/8/19~~ at New Delhi by.

  
**(Sunil Chowdhary)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.

2. The Manager,

Alka Hotel located at 16/90, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.
10. Fire check door (FCD) in staircase and carbon monoxide (CO) detectors installed with in three months other wise FSC issued may be treated as suspended.

