

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001

NO.F6/DFS/MS/School/2019/SZ/ 1588

Dated: 9/8/19

FIRE SAFETY CERTIFICATE

Certified that the Gauttam Model Public School, Located at Street No. 14, Sadhnagar, Palam Colony, New Delhi-110045, comprised of ground plus two upper floors the school is running at ground & first floor (having total 12 rooms including class rooms, office & reception etc.& second floor is being used as a residence of the owner) was Issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2016/SZ/SZ/510 dated 1.4.2016. The said school building was re-inspected by the officer concerned of this department on 23.7.2019 in presence of Smt. Punam Sharma (Principal) and found that the Premises/Building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" for ground plus one upper floor with effect from... 9/8/19... for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on 9/8/19 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Ph.011-26189168

Copy to:-

1. The Director (Education), Govt. of NCT of Delhi, old Secretariat, Delhi-110054.
2. The Manager, the Gauttam Model Public School, Located at Street No. 14, Sadhnagar, Palam Colony, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

