

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2019/ 1600

Dated: 09/08/19

FIRE SAFETY CERTIFICATE

Certified that **M.C.D. Primary School (1st & 2nd shift), Inder Puri, New Delhi-110012**, comprised of ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/687 dated 06.05.2015. The school building was re-inspected by the officer concerned of Delhi Fire Service on 30.07.2019 in the presence of Smt. Rajni, School Incharge and found that the school management (N.D.M.C.) have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational", with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 09/08/19 at New Delhi by.


(Rajesh Panwar)
Dy. Chief Fire Officer
Ph.01126179168

Copy to: -

1. The HOS, N.D.M.C. Primary School, Inder Puri- I, New Delhi- 110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

