

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / *School/1585*

Dated: *08/08* /2019

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidhyalaya** located at **A-Block, P. No. 5, Jahangir Puri, Delhi** comprised of **ground and 04 upper floors (New building)** owned/ occupied by the **Sarvodaya Kanya Vidhyalaya** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 17.06.2019 in the presence of Sh. Pardeep Aluwalia and that the building/premises is fit for occupancy Class "Group B Educational" with effect from*08/08/19*... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*08/08/19*..... at New Delhi

(Signature)
(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Sarvodaya Kanya Vidhyalaya, A-block, Jahangir Puri, Delhi.
3. The Executive Engineer, Technical Centre Building, Wazirpur Industrial Area, Delhi-110052.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidhyalaya, P.No. 5, A-block, Jahangir Puri , Delhi.
2. Type of Occupancy : Educational
3. Type of Case : New Case (New building- G + 04 upper floors)
4. Details of previous NOC : --
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 17/06/2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Pardeep Aluwalia
9. Year of Construction : 2016
10. Applicant's letter No. : DSIIDC/EE (ED-I)/SKV/FIRE/NOC/2019-20/381 dated: 02.05.2019

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 06m | 06m | MR |
| | • Gate width | 4.5m | 4.5m | MR |
| | • Width of internal road | 06m | 06m | MR |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 03 | 03 | MR |
| | • Basements | | | |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50m | 1.50m each | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 01 | Provided | MR |
| | e. Width of Corridor | Required | Provided | MR |
| f. Door Size | 1 m | 1.20m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |

K

