

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / *School 1583*

Dated: *08/08/2019*


FIRE SAFETY CERTIFICATE

Certified that the **Yuva Shakti Model School** located at **Rama Vihar, Delhi-110081** comprised of **Ground + Two upper floor** owned/ occupied by the **Yuva Shakti Model** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2016/School/1117 dated 08.07.2016** The premises was re-inspected by the officer concerned of this department on **22.07.2019** in the presence of **Sh. Parveen Kumar (Principal)** observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from*08/08/19*..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*08/08/19*..... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Yuva Shakti Model School, Rama Vihar, Delhi-110081.

2/12

INSPECTION REPORT

1. Name & address of the building : Yuva Shakti Model School, Rama Vihar, Delhi-110081.
2. Type of Occupancy : Educational (Ground +02)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2016/School/1117 Dated: 08.07.2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 22/07/2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr. Praveen Kumar (Principal)
9. Year of Construction : 2007
10. Applicant's letter No. : No.YMS/FS/2019/03 Dated: 03.07.2019

Plot Area-2652 sqm Covered Area:3134 sqm Students—700 nos class rooms —49 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.25m, 1.15m & 1.08m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	1 m	1 m	MR	

✓