

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2019/ 1646

Dated : ~~20/8/19~~

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Aggarwal House located at 4/14A, Asaf Ali Road, New Delhi comprised of Basement + Ground + 04 Upper floors was granted FSC by this department vide letter No.F6/DFS/MS/GH/2019/NDZ/477 dated 29/03/16. The premises was re-inspected by the officer concerned of this department on 08/08/19 in the presence of Smt. Laxmi Aggarwal and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Mercantile & Business with effect from ~~20/8/19~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~20/8/19~~ at New Delhi by.

(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Commissioner, NDMC, Civic Center, Minto Road, New Delhi.
2. Smt. Laxmi Aggarwal,  
M/S Aggarwal House located at 4/14A, Asaf Ali Road, New Delhi - 110002.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

