

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Audi/SZ/2019/ 1633

Dated: 19/8 /2019

FIRE SAFETY CERTIFICATE

Certified that the **Main Auditorium & Mini Auditorium-I & II** located at Baha'i House of Worship, Lotus Temple Road, Bahapur, Kalkaji, New Delhi-110019, comprised of ground floor only was issued FSC by this department vide letter No. F6/MS/DFS/Audi/2016/SZ/120 dated 18/01/2016. The premise was re-inspected by officer concerned of this department on 26/07/2019 in the presence of Mr. Jay Prakash Ambrate (Maint. Manager) and found that the said auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class "**Assembly Group-D**" with effect from 19/8/ 2019 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/8 /2019 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250

Copy to: -

1. The Manager M/s Baha'i House of Worship, Lotus Temple Road, Bahapur, Kalkaji, New Delhi-110019
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate: -

1. The owner/occupier shall occupy the auditorium only after issue of license by the Dy. Commissioner of concerned revenue District of NCT of Delhi as notified by Revenue department, Govt. of NCT of Delhi vide Delhi Gazette notification dated 09/01/15.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration **every year in form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (I) of rule 37] along with a copy of this Certificate, **six month** prior to its expiry."

