

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No. F.6/DFS/MS/CNG/2019/SZ/ 1657

Dated: 21/8/19

FIRE SAFETY CERTIFICATE

Certified that the **CNG Dispensing Station at Jail Road**, Opp. Tihar Jail, Hari Nagar, New Delhi, comprised of ground floor only and offices at ground floor plus one upper floor, owned/occupied by Indraprastha Gas Limited, was issued NOC by this department vide letter no. F.5/(3A)/DFS/ CNG/2007/285 dated 29.06.2007 for 09 dispenser and 02 compressor. The premises was re-inspected by the officer concerned of this department on 25.04.2019 & 04.07.2019 in the presence of Sh. Sanchit Sehrawat (Dy. Manager F & S) and found that now there are 16 dispenser & 04 compressor at CNG Dispensing station Jail road have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**CNG Dispensing Station**) is fit for occupancy class Group "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....21/8/19.....at New Delhi.

(ATUL GARG)
CHIEF FIRE OFFICER

Copy to:-

The Vice-President (F&S),
Indraprastha Gas Limited, IGL Bhawan, Plot No.-4,
Community Centre, Sector-9, R.K.Puram, New Delhi-110022

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : CNG Dispensing Station at Jail Road, Opp. Tihar Jail, Hari Nagar, New Delhi
2. Type of Occupancy : Group "J" Hazardous
3. Type of Case : Renewal/Addition
4. Details of Previous NOC : F.5/(3A)/DFS/ CNG/2007/285 dated 29.06.2007
5. Fire Safety directives letter No : F.5/(3A)/DFS/2006/CNG/418 dated 02.11.2006
6. Date of inspection : 25.04.2019 & 04.07.2019
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Sanchit Sehrawat (Dy. Manager F & S)
9. Year of Construction : 2006
10. Applicant's letter No. : IGL/F&S/2019/15/73/1 dated 27.03.2019

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtrs. NA NA	Provided Directly accessible from road NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	24 no.'s DCP & CO ₂ ISI	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Gas and flame detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required NA NA Required	Provided Office at GF NA Provided	MR NA NA MR

8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Battery backup 			

2/11

CNG dispensing station is at Ground floor only and offices are at ground floor plus one upper floor

20.	Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Provided	MR
		DCP flooding system for roof mounted cascades	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings communicated by this department vide letter no. F.6/DFS/MS/2015/2189 dated 26.10.15 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.5/(3A)/DFS/CNG/2007/285 dated 29.06.2007 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Water mist cum Foam trolley are provided instead of water spray system in cylinder filling shed with underground water tank and boosting arrangement as per the minutes of meeting vide letter no. F.2/DFS/HQ/2004/685/D dated 30.04.2004.

An undertaking has been submitted by Sh. Alok Sharma (Vice President F & S), that nothing contravention of the Explosives Act 1884 & Rules their under, Gas Cylinder Rules 2016 and Static and Mobile pressure Vessels (Unfired) rules, 2016 as modifies up to date at the above mentioned CNG dispensing station.

Sandeep
05/8/19

Signature of Inspecting Officer
Name:- SANDEEP DUGGAL
Designation:- Asstt. Divisional Officer



DO (SW)

06/08/19

DCFO (S2)

Samp
07/8

CFD
08/08/19

FTMS

Any/our

FT. letter is put up for signature please

