

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / W2/1656

Dated: 21/8/2019


**FIRE SAFETY CERTIFICATE**

Certified that N.D.M.C Primary Boys School located at Sector-4/II, Rohini, Delhi- 110085 comprised of 02 Blocks (Ground floor & Ground + 01 upper floor) owned/occupied by N.D.M.C Primary Boys School was granted FSC by this department vide letter no. No.F6/DFS/MS/2015/SCHOOL/WZ/1200 dated 08.07.2015 The premises was re-inspected by the officer concerned of this department on 26.07.2019 in presence of Smt. Suman Arora (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ...21/8/19..... for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on .....21/8/19..... at New Delhi

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, N.D.M.C Primary Boys School, Sec-4/II, Rohini, Delhi- 110085.

2/6

**INSPECTION REPORT**

1. Name & address of the building : N.D.M.C Primary Boys School, Sec-4/II, Rohini, Delhi- 110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal 02 Blocks(Ground & Ground +1 upper floor)
4. Details of previous NOC : No.F6/DFS/MS/2015/School/WZ/1200 Dated 08.07.2015
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 26.07.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Smt. Suman Arora (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : Nil Dated: 06.04.2019

Plot Area:4600sqm

Covered Area: 1800sqm

No of class rooms – 22 nos

No of students---800nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.70m	MR(old case )
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1.5m & 1m	MR
		NA	NA	NA
	• Basements			
		NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	1m x2	1.m x2 double door	MR
e. Width of Corridor				
f. Door Size				

