

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/WZ/2019/ 1654

Dated: 21/08/2019

FIRE SAFETY CERTIFICATE

Certified that the **North Delhi M.C. Pry. School** Located at **A-1, Ashok Vihar Pase-II, Delhi - 110052** comprised of Ground +1 Upper Floor (**Ground Floor block abandoned**) owned/ occupied by **North Delhi M.C. Pry. School** have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on **29-07-2019** in the presence of **Smt. Geeta Gupta (Principal)** and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from **21/8/19** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on**21/8/19**... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to: 1. North Delhi M.C. Pry. School, A-1, Ashok Vihar Pase-II, Delhi -110052.
2. Directorate Of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **North Delhi M.C. Pry. School Located at, A-1, Ashok Vihar Pase-II, Delhi -110052.**
2. Type of Occupancy : Educational Ground +1 Upper Floor (**Old Block, Ground Floor Only abandon**)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Date of inspection : 29/07/2019
6. Name of the Inspecting Officer : Uday vir singh, ADO (WP)
7. Name and designation of Officer
from the building side : Smt. Geeta Gupta (Principal)
8. Year of Construction : 2004
9. Applicant's letter No. : Nil dated 15/05/2019

No. of Students=453
 No. of class rooms=18
 Plot area=2816sqm
 Covered Area—1507qmt

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible Accessible NA	Provided 280cm Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5 mtrs.	1x180 cm & 1x150 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	210cm Provided	MR
	f. Door Size	1 mtr	110cm Provided (Double Door)	MR

