

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2019/ 1652

Dated: 21/08/2019

FIRE SAFETY CERTIFICATE

Certified that the **Prabhu Dayal Public School**, Located at **Primary Wing, BM Block, Shalimar Bagh, Delhi – 110034** comprised of Basement+ Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/10/393 Dated-09/02/2010 The premises was re inspected by the officer concerned of this department on 02/08/2019 in the presence of Ms. Bimla Bhatia (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC part-IV/DOE Circular 262–362 Dated 17-01-2005 and that the premises is fit for occupancy class “Educational” Group B with effect from 21/8/19 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 21/8/19 ... at New Delhi by.

(Dharpal Bhardwaj)
DY. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, Prabhu Dayal Public School, Dakshni Block- A, Shalimar Bagh, Delhi –34.
2. Director of Education, Old Secretariat, Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Prabhu Dayal Public School, Located at Primary Wing, BM Block, Shalimar Bagh, Delhi – 110034.
2. Type of Occupancy : Educational (Basement + Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/10/393 Dated-09/02/2010
5. Fire Safety directives Letter No. : Cir 262–362 Dated 17-01-2005
6. Date of inspection : 02/08/2019
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Ms Bimla Bhatia (Manager)
9. Year of Construction : 1989
10. Applicant's letter No. : 442 Dated -11/06/2019

Total Area = 1.57 acre
 Covered Area = 2975sqm
 Class rooms = 27
 No. of students = 1104

S No	Minimum standards on fire prevention and fire safety U/R 33	Cir 262–362 Dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 355cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 02 02 	<ul style="list-style-type: none"> 03 Provided 02 	<ul style="list-style-type: none"> MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 150cm 150cm&125cm 	<ul style="list-style-type: none"> 2x143cm & 1x174cm 1x1.43m, 1x1.25m 	<ul style="list-style-type: none"> MR MR(Old case)
	d. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	e. No of continuous staircase to terrace			
		NA	NA	NA
	f. Width Of Corridor	1.5m	263cm Provided	MR
	g. Door Size	1mtrs	1m provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 nos. ABC & CO ₂ ISI marked	16 Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	100mm 02 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	NA NA	NA NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ No. of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm, 180 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/10/393 Dated-09/02/2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: All the shortcomings communicated earlier have been completed.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ASO/WP

Signature of the Inspecting Officer
 Name
 Designation

ASO/WP

Pl. see requirement of U.G. Tank as per 262-362

[Signature]
 6/8/19

ASO/WP

Sir, as mentioned in previous NOC (placed at C/2) & details of School provided by School principal (placed at C/4) the covered area of the school is less than 5000 m². Hence U.G. Tank is not required.

[Signature]
 6/8/19

ASO/WP

[Signature]
 6/8/19

[Signature]
 (W2)

[Signature]
 9/11/19

ASO/WP
 Day view

letter is not ok for
 ble