GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2019/ 1713 Dated :-- 3/9/19

FIRE SAFETY CERTIFICATE

Certified that the **M/s Awesome International** located at **4017-21, Gali No. 2, Bagichi Ram Chander, Kaseruwalan, Pahar ganj, New Delhi-55** comprised of **Ground + 03 Upper floors, Ground floor (Reception + 01 guest rooms), 1st floor (05 guest rooms), 2nd floor (05 guest rooms) and 3rd floor (05 guest rooms), total 16 guest rooms,** owned/occupied by M/s Awesome International have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 23/08/2019 in the presence of **Mr. Lalu** that the premises is fit for occupancy class **Residential, Sub Division-A-1 as above 16 guest rooms only** with effect from --- 3/9/19 ---- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued --- 3/9/19 ---at New Delhi by.

(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
2. The Manager,
   M/s Awesome International,
   4017-21, Gali No. 2, Bagichi Ram Chander, Kaseruwalan, Pahar ganj, New Delhi-55.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.
10. Fire check door (FCD) in staircase and carbon monoxide (CO) detectors installed with in three months other wise FSC issued may be treated as suspended.

INSPECTION REPORT

1. Name & address of the building — M/s Awesome International at 4017-21, Gali No. 2, Bagichi Ram Chander, Kaseruwalan, Pahar ganj, New Delhi-55
2. Type of occupancy:- — Residential, Sub Division-A-1
   Ground + 03 Upper floors, Total 16 Guest rooms
   Ground floor (Reception + 01 guest room)
   1st floor (05 guest rooms), 2nd floor (05 guest rooms) and 3rd floor (05 guest rooms)
3. Type of case:- — New Case
4. Details of previous FSC:- — N/A
5. Fire safety directives No.- — N/A
6. Date of inspection:- — 23/08/19
7. Name of the inspecting officer:- — Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer From the building side:- — Mr. Lalu
9. Year of construction:- — 2018
10. Applicant's letter No:- — 7099-7104/Jt. C.P/Lic.(H) dated 25/06/2019.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	**Access to Building**			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5 mtr. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	**Compartmentation**			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Provided	MR
5.	**Fire Extinguishers**			
	1) Total numbers	15 Nos.	15 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

6.	**First-Aid Hose Reel**			
	1) Total number of eachfloor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	**Automatic Fire Detection & Alarming System**			
	1) Type of detectors **(Carbon monoxide)**	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	**Yard Hydrants**			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	**Pumping Arrangement**			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	**Captive Water Storage for Fire Fighting**			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10, 000 ltr.	10,000 ltr.	MR

N/3

15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	**Stand by Power Supply**	Required	Provided	MR
18.	**Refuge Area**	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	**Fire Control Room**	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risk, if any:**			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- ADO (CC)

DO/CD

26/08

DFO (NDZ)

27/8

C.F.O - IV

FIPS