

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1703

Dated: 28/8 /2019


FIRE SAFETY CERTIFICATE

Certified that the **Decent Public School** located at **H-Block, Sector-03, Rohini, Delhi-110085** comprised of **Ground and 03 upper floors** only owned/ occupied by **Decent Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/MS/DFS/2004/2575 dated 25.10.2004**. The premise was re-inspected by the officer concerned of this department on **27.07.2019** in the presence of **Mrs. Renu Gupta, Principal** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **...28/8/19.....** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on **28/8/19.....** at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, Decent Public School, H-Block, Sector-03, Rohini, Delhi-110085.

INSPECTION REPORT

1. Name & address of the building :Decent Public School, H-Block, Sector-03, Rohini, Delhi-110085.
2. Type of Occupancy :Educational
3. Type of Case :Renewal - Ground & 03 upper floors
4. Details of previous NOC :F-6/MS/DFS/2004/2575 dated 25.10.2004
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2002/2046 dated 25.10.2002
6. Date of inspection : 27.07.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mrs. Renu Gupta, Principal
9. Year of Construction : 2003
10. Applicant's letter No. : dairy no. 9330 dated: 15.04.2019

Plot Area-4681.81m² Covered Area: 2150 m² apprx.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6 m	MR
	• Gate width	4.5m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	2	MR
	e. Width of Corridor	1.50m	Provided	MR
f. Door Size	1 m	1.00 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

AM

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	17 nos	18 nos	MR
	<ul style="list-style-type: none"> Types 	ABC/Co2	ABC-18	MR
	<ul style="list-style-type: none"> ISI marking 	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA

1

2/15

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	950 lpm	Provided	MR
		40m	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 ltr.	50,000 ltr.	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000ltrs	10,000ltrs	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			

h

n/b


2


	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no 2575 dated 25.10.2004 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

Dy. Insp.



19/8/19



Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN

~~ADD~~ R-N-F-T

As approved, f.t. letter is put up for your signature pl.

Dy. Insp.


27/8/19


23/8/19

not cell