

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2019/SZ/ 1720

Dated: 05/09/19

FIRE SAFETY CERTIFICATE

Certified that the Bapu Adarsh Vidhalaya (Sec.) located at R Block, New Rajinder Nagar, New Delhi-110060, comprised of ground floor plus one upper floor was issued Fire Safety Certificate Vide this department letter no. F6/DFS/MS/School/2015/SZ/207 dated 11.2.2015 for ground floor. The said school was re-inspected by the officer concerned of this department on 24.8.2018 & found that the management has added one more upper floor (First floor) & have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. Estate/CC/Fire Safety/2011/3298 dated 01.03.2011, and that the building is fit for occupancy class B "Educational building" with effect from05/09/19.....for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on05/09/19..... at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: - 011-23414250


Copy to:-

1. The Director, (Education), G.N.C.T. of Delhi, Old Secretariat, N. Delhi-110054.
2. The Vice-Principal, the Bapu Adarsh Vidhalaya (Sec.) located at R Block, New Rajinder Nagar, New Delhi-110060.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADD DATE

