

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO:F6/DFS/MS/School/2019/SZ/ 1721

Dated: 05/09/19

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidhalaya, Parsad Nagar, North Delhi Municipal Corporation, Karol Bagh, New Delhi-110005 (Ward No.95) , comprised of ground floor was issued fire safety certificate by this department vide letter no. F6/DFS/MS/school/SZ/2016/1448 dated 27.9.2016. The said school building was re-inspected by the officer concerned of this department on 14.8.2019 in presence of sh. Tika Ram (In charge) & found that the management has constructed one more upper floor & now building comprised of ground plus one upper floor and have complied with Fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from...05.09.19, for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on05/09/19 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph. 011-23414250



Copy to:-

1. The Director (Education) SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.
2. Sh. Tika Ram (In Charge) that the Nigam Pratibha Vidhalaya, Parsad Nagar, North Delhi Municipal Corporation, Karol Bagh, New Delhi-110005 (Ward No.95).

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

