

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2019/WZ/ 1821

Dated: /28/09/2019

FIRE SAFETY CERTIFICATE

Certified that the building M/s Bikanervala Foods Pvt. Ltd. Located at, Shop No-01,2,3 & 4 Ground Floor, Plot No-3, Community Center, Road No-44, Pitampura Delhi-110034 in a building comprised of Two Basement+Ground+07 Upper Floors (FSC issued to mall vide F6/DFS/MS/2018/WZ/42 Dated-07/01/2019) owned/ occupied by M/s Grand Bikaner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23/08/2019 in the presence of Mr. Mukesh (Employee) and found that the said building that the premises is fit for occupancy class "Assembly" Group D(Ground Floor Only) with effect from 20/9/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/9/19 at New Delhi by.

(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:1. The Dy Health Officer, Keshav Puram Zone,NDMC, Public Health Department, A-1 Block Keshav Puram Zone Delhi.
2. M/s Bikanervala Foods Pvt. Ltd. Located at, Shop No-01,2,3 & 4 Ground Floor, Plot No-3, Community Center, Road No-44, Pitampura Delhi-110034

Following fire safety directives must be adhered to:-

1. **The FSC is valid for to run the restaurant at Ground Floor Only**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **M/s Bikanervala Foods Pvt. Ltd.** Located at,
**Shop No-01,2,3 & 4 Ground Floor, Plot No-3, Community Center, Road
No-44, Pitampura Delhi-110034**
2. Type of Occupancy : Assembly at Ground Floor (The Building comprised of
Two Basement+Ground+07 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Letter No. F6/DFS/MS/2018/WZ/42 Dated-
07/01/2019(Issued to Building)
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2014/331 Dated-15/12/2014 (
Issued to Building)
6. Date of inspection : 23/08/2019
7. Name of the Inspecting Officer : Udai Vir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Mukesh (Employee)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil Dated 09/08/2019

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	3 Provided	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	2.3 m & 1.5m	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System	common with mall		
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	02nos.	4 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels	Common with mall		
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	6.5 mm	Provided	MR
7.	Automatic fire detection and alarming system	common with mall		
	<ul style="list-style-type: none"> • Type of detectors 	NR	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	NR	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NR	NR	NR
	<ul style="list-style-type: none"> • Alternate source of power 	NR	NR	NR
	<ul style="list-style-type: none"> • Hooters' Location 	NR	NR	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NR	NR	NR
11.	Internal Hydrants: common with mall			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements: common with mall			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	2850 lpm	NA
		NA	88m	NA
		NA	2	NA
		NA	2x180 lpm	NA
		NA	88m	NA
		NA	2850 lpm	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		900 lpm	MR(As pumps at G level at higher side)
		40 mDo...
		RequiredDo...
		RequiredDo...
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	200000 ltrs	NA
		NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	20000 ltrs	NA
15	Exit Signage	NA	Provided	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNil.....

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation AD/DO/WP

Signature of the Inspecting Officer
 Name
 Designation

AD/DO Mukherjee 26/8/19

~~AD/DO/WP~~ where is reference from licensing Dept.

AD/DO/WP Mukherjee 26/8/19
 Sir reference letter is placed at C/7.

AD 27/8

AD/DO Mukherjee 27/8/19

~~AD/DO/WP~~
 C/O Mukherjee 27/8/19
 FI/PL

AD/W/AD/DO/WP

list of for site file