

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2019/ 1819

Dated: 19/09/19

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Damdi Food** (A unit of Damdi Food Pvt. Ltd) at 46, First Floor, Basant Lok, Vasant Vihar, New Delhi-110057, comprised of basement, ground, mezzanine plus three upper floors but restaurant running at First floor was issued NOC in the name of M/s **Hash Restaurant** by this department vide letter No. F.6/MS/DFS/EH/2010/1113 dated 20/08/2010. The premise was re-inspected by the officer concerned of this department on 14/09/2019 in the presence of Sh. Vivek Kumar (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly, Group-D**" (Restaurant) with effect from 19/09/2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/09/2019 at New Delhi by

(Atul Garg)  
Chief Fire Officer  
Tel. 011-23414250

Copy to: -

1. The Dy. Health Officer, South Zone, South Delhi Municipal Corporation, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016
2. Sh. Vivek Kumar, M/s Damdi Food (A Unit of Damdi Food Pvt. Ltd) at 46, First Floor, Basant Lok, Vasant Vihar, New Delhi-110057

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."



## INSPECTION REPORT

1	Name & Address of the Building	M/s <b>Damdi Food</b> (U/o Damdi Food Pvt. Ltd) at 46, FF, Basant Lok, Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Assembly, "Group-D" (Eating House at First Floor)		
3	Building Comprised of	Basement, Ground, Mezzanine + 03 upper floors.		
4	Type of Case	Change of Name		
5	Details of Previous NOC	F.6/MS/DFS/EH/2010/1113 dated 20-04-2010 in the name of M/s Hash Restaurant.		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04-04-2005 (N/1)		
7	Date of Inspection	14-09-2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Vivek Kumar (Manager)		
10	Year of construction	1978		
11	Applicant letter No.	DHO/SZ/2019/D-810 dated 06/08/2019		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As Per Old NOC</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Accessible	6m	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25 mtr	1.17m & 1.06m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	2 Exits	1.17m & 1.06m	MR (old case)
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Restt. area	12 ACPH	Provided	MR
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	ISI marked	06 Nos	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	Hose-reel	One	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-



8	<b>MOEFA</b>	Required	Provided	✓	MR
9	<b>Public Address System</b>	-NA-	-NA-		-NA-
10	<b>Automatic Sprinkler System</b>				
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Upper floors. / Restt. Area</li> </ul>	Required	Provided	✓	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-		-NA-
11	<b>Internal Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	100mm	Provided	✓	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-NA-	-NA-		-NA-
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-NA-	-NA-		-NA-
13	<b>Pumping arrangements.</b>				
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>				
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>				
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 & 225 LPM	450 & 225 LPM	✓	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40m	40m	✓	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided		MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided		MR
14	<b>Captive water storage for fire fighting.</b>				
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	Required	Provided	✓	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	5,000 Ltr	10,000 Lts	✓	MR
15	<b>Exit Signage.</b>	Required	Provided	✓	MR
16	<b>Provision of Lifts.</b>				
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	-NA-	-NA-		-NA-
17	<b>Standby Power Supply</b>	Required	Provided	✓	MR
18	<b>Refuge Area</b>				
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Location</li> </ul>	-NA-	-NA-		-NA-
19	<b>Fire Control Room.</b>				
	<ul style="list-style-type: none"> <li>Detector system panel.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Flow switch panel.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>PA system panel.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Battery backup.</li> </ul>	-NA-	-NA-		-NA-
	<ul style="list-style-type: none"> <li>Building floor plan.</li> </ul>	-NA-	-NA-		-NA-
20	<b>Special Fire Protection System for the Protection of Special Risk, if any.</b>	-NA-	-NA-		-NA-

N/13

M/s Damdi Food (U/o Damdi Food Pvt. Ltd), 46, FF, Basant Lok, Vasant Vihar, New Delhi-110057

The fire protection system provided in the restaurant premise were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/MS/DFS/EH/2010/1113 dated 20/04/2010 in the name of M/s Hash Restaurant, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended in the name of M/s Damdi Food (A unit of Damdi Food Pvt. Ltd).

Accordingly, DFA is put up for approval and signature please.

~~hamed~~  
16/9/19

Signature of Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

~~hamed~~  
16/9/19

~~DO (SD)~~

DCFO(S2) → on leave

~~CFO (HOS) / MY~~  
17/9/19  
f i ns

~~ADP(S)~~

Sir. A. F. T. letter p.m. up for signature please

~~hamed~~  
18/9/19  
ADO (S2)

~~ADP(S)~~  
18/9/19

ms