

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2019/NDZ/ 1855

Dated:

24/9/19

FIRE SAFETY CERTIFICATE

Certified that the Oracle Public School C-82,Matke Wali Gali,Gali No.11, Chouhan Banger,New Seelampur,Delhi-53, comprised of ground plus three upper floors was issued FSC vide letter no. F6/MS/DFS/2016/NDZ/1594 dated-27/10/16.The School building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC Part IV and verified by the officer concerned of this department on 18/09/19 in the presence of Mohd. Arif Ansari (Manager) of the school and found that the building is fit for occupancy class 'B' 'Educational Building' with effect from24/9/19. for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....24/9/19.....at New Delhi by



(Sunil Chawdhary)

Dy. Chief Fire Officer

OK

To,

The Manager,
Oracle Public School C-82,Matke Wali Gali,Gali No.11,
Chouhan Banger,New Seelampur,Delhi-53

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi.

- N/12
1. Name & address of the building : Oracle Public School C-82, Matke Wali Gali, Gali No.11, Chouhan Banger, New Seelampur, Delhi-53.
 2. Building is comprised of : G+3 upper floors
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/MS/DFS/2016/NDZ/1594 dated-27/10/16
 6. Fire Safety Circular No. : NBC Part-IV
 7. Date of Inspection : 18.09.2019
 8. Name of the Inspecting officers : ADO R.K. Yadav
 9. Name and designation of Officer from the building side : Mohd. Arif Ansari (Manager)
 10. Year of Construction : 2008
 11. Applicant's letter No : OPS/2019/31 Dated 27/08/16

S N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	05 M	MR (old accepted)
	• Gate width	N/A	N/A	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 No.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M 2.075M	1.5 M & 1.20 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 Nos	1 Nos	MR
	g. Width of Corridor	1.5 M	1.5 Mtrs	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 Nos.	08 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/13

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 Nos	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the Pump	40M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/4

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. This department had issued already NOC vide letter no. F6/MS/DFS/2016/NDZ/1594 dated-27/10/16.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R. K. Yadav
18/11/2018

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO(LN)

DO(ED)

[Signature]
19/11

DT: (F6) NDZ

[Signature]
24/11/18

Et. pl.

DO(ED)

ET better is put up for sign. please

DT: (F6) NDZ

[Signature]
18/11

[Signature]
24/11/20