GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2019/SZ/ 1812 Dated: 19/09/2019

FIRE SAFETY CERTIFICATE

Certified that the Smt. Sarti Devi Public School Located at Village Tajpur Khurd Najafgarh (Sector-19 Dwarka) New Delhi-110071), comprised of ground plus two upper was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/1291 dated 17.8.2016. The said School building was re-inspected by the officer concerned of this department on 31.8.2019 in presence of Mr. Praveen Kumar (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class B "Educational building" with effect from..19/09/19..... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on .....19/09/19..... at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Ph. 011-26189168

Copy to:-

1. The Director, (Education), GNCT of Delhi, Old Secretariat, Delhi-110054.
2. The Manager Smt. Sarti Devi Public School Located at Village Tajpur Khurd Najafgarh, (Sector-19 Dwarka) New Delhi-110071.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADO
Dwarka

INSPECTION REPORT

1	Name & address of the building	Smt. Sarti Devi Public School, Tajpur Khurd, Najafgarh, New Delhi-110071		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS SCHOOL/2016/SZ/1291 dated 17.8.2016		
5	Fire safety directives letter No	Old Case		
6	Date of inspection	31.8.2019		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh.Praveen Kumar (Manager)		
9	Year of construction	Before 2006		
10	Applicant's letter No.	No.888/19 Dated 13.8.2019	**Ground plus Two upper floors**	
S. NO.	**Minimum Standards on fire prevention and fire safety U/R 33**	**NBC Requirements/ letter dated 17.8.2016**	**Provided at site**	**Remarks MR / NMR**
1	**Access to building**			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	**Number, width Type & arrangement of exits**			
	a. Number of staircases			
	1. Upper floors	One	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs	1.50 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Two	MR
	e. Width of corridor	1.50 Mtrs.	1.50 Mtrs.	MR
	f. Door size	1 Mtr.	92x202 Cms.	MR Being old case
3	**Compartmentation.**			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	Sealed	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	**Smoke Management system.**			
	basement	N/A	N/A	N/A
		12 A/C change		
	upper floors		Natural Ventilation	MR

5	**Fire Extinguishers**			
	total numbers	Two at each floor CO2 OR ABC	8 Nos.	MR
	Types	ABC	CO2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR
6	**First-Aid Hose Reels.**			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 m	5 m	MR
7	**Automatic fire detection and alarming system**			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	**MOEFA**	N/A	N/A	N/A
9	**Public Address System.**	N/A	N/A	N/A
10	**Automatic Sprinkler System.**			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants**			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	**Yard Hydrants.**			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	**Pumping arrangements**			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2.Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	30 Mtrs.	30 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	**Captive water storage for fire fighting**			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	**Exit Signage.**	Required	Provided	M/R

N/14

16	**Provision of lifts.**			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	**Standby power supply**	Required	DG Set 50 KVM	MR
18	**Refuge Area.**			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	**Fire control room**			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	**Special Fire Protection systems for protection of special risks, if any;**	Required	CO2 Fire Extinguisher provided near electrical panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2016/SZ/1291 dated 17.08.2016 is recommended.

Accordingly DFA is put up for your approval and signature please.

2/8/19

S.P. Bhardwaj
ADO (Dwarka)

DO/SW

11/8/2019

DCFO (S2)

12/9.

DO/SW

13/9

ADO (Dwk)

DIVISIONAL OFFICER (S2) Diary No. 348 Dated 11/9/19

DELHI FIRE SERVICE Dy. Chief Fire Officer (SZ) Diary No. 888 12/9/19