

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/BNQT./2019/SZ 2098

Dated:

31/10/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Golden Gate Banquet Hall, Ground floor, Plot No. B-18, Maya Puri, New Delhi, is running on ground floor of a building comprised of basement, ground plus one upper floor owned/ occupied by M/s Golden Gate Banquet Hall. The building was inspected by the officers concerned of this department on 19.10.2019 in the presence of Sh. Rohit Kalra (Owner) and found that the owner/occupier have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor Only**) is fit for occupancy building Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....31/10/19.....at New Delhi.

(ATUL GARG)
CHIEF FIRE OFFICER

8

Copy to:-

1. The Executive Engineer (Building-I),
S.D.M.C, Vishal Enclave, Rajouri Garden,
New Delhi-110027
2. The Manager,
M/s Golden Gate Banquet Hall,
Plot No. B-18, Maya Puri, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Golden Gate Banquet Hall, Plot No. B-18, Maya Puri, New Delhi
2. Type of Occupancy : Assembly D-3
3. Type of Case : New
4. Details of Previous NOC : N.A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2019/2732 dated 08.05.2019
6. Date of inspection : 19.10.2019
7. Name of Inspecting Officer : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Rohit Kalra (Owner)
9. Year of Construction : Before 2010 (conversion dated 04.08.2010 from Industrial to commercial)
10. Applicant's letter No. : Nil dated 23.09.2019

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL-16/NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (09 mtrs.) 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 no.'s	Provided	MR
	• Basements	02 no.'s	Provided	MR
	b. Width of staircases			
	• Upper Floor	150 & 120 cms	150 cms & 120 cms	MR
	• Basements	150 & 150 cms	150, 150 cms & 01 ramp	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	200 cms	Opening in hall	MR
	f. Door Size on Ground floor	200 cms (03 no.'s)	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Exhaust fans are provided	MR
	• Upper floor	Required	Exhaust fans are provided	MR
5.	Fire Extinguishers			
	• Total numbers on each floor	06 no.'s	Provided	MR
	• Types	ABC/CO ₂ /W CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

Son

	<ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	GF	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Required	In hall	MR
8.	MOEFA With talk back system	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required 100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
		25000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

2/8

19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings communicated by this department vide letter no. F.6/DFS/MS/BNQT/2019/SZ/5628 dated 17.09.19 have been complied.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- Building is comprised of Basement (intended to use as car parking), ground plus one upper floor but banquet hall is running at Ground floor only and first floor having semi pucca roof was found vacant (intended to use as office) at the time of inspection.

[Signature]
24/10/19

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer



[Signature]
23/10/19

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

Dy. C.F.O. (South Zone)

[Signature]
24/10

[Signature]
29/10/19

F.F.S

DD/SW

[Signature]
22/10

