

**GOVERNMENT OF NATION CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/School/2019/SZ/2113

Dated: 06/11/19

**FIRE SAFETY CERTIFICATE**

Certified that the Heera Public School located at Samalka, Gurgaon Road, New Delhi-110037 comprised of ground plus two upper floors owned/occupied by Heera Public School was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2016/SZ/1390 dated 08/09/2016. The premises was re-inspected by officer concerned of this department on 23/10/2019 in presence of Mr. Pawan Vatts (In Charge) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/11/19 at New Delhi by

  
(Rajesh Panwar)  
Dy. Chief Fire Officer  
Tel. 011-26189168

Copy to: -

1. The Principal, Heera Public School, Samalka, Gurgaon Road, New Delhi-110037
2. Directorate of Education, G.N.C.T Delhi, Old Secretariat, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/11

### INSPECTION REPORT

1	Name & Address of the Building	Heera Public School, Gurgaon Road, Samalka, New Delhi-110097		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground Plus Two Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2016/SZ/1390 dated 08/09/2016.		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23/10/2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Pawan Vatts (Incharge)		
10	Year of construction	1997		
11	Applicant letter No.	12/2019 dated 16/07/2019		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As Per Old NOC Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1.</b>	<b>Access to Building.</b>			
	• Road width	9m	12m ✓	MR
	• Gate width	5m	5m ✓	MR
	• Width of internal road	-NA-	-NA- ✓	-NA-
<b>2.</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	04 Nos	04 Nos ✓	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floor	1.5m/75cm	1.22,1.22,1.22 & 1.15m ✓	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Basement	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	1no	01no ✓	MR
	<b>e) Width of corridor</b>	1.5m	1.5m ✓	MR
	<b>f) Door size</b>	1mtr	Provided ✓	MR
<b>3.</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	12 Nos	26 Nos ✓	MR
	• Types	ABC/CO2	Co2,ABC & WCO2	MR
	• ISI Marking	ISI mark	Provided	MR

6.	<b>First Aid Hose Reels.</b>			MR
	Total numbers on each floor.	02nos	02nos ✓	MR
	<ul style="list-style-type: none"> <li>• Length of hose-reel hose.</li> </ul>	30m	Provided ✓	MR
	<ul style="list-style-type: none"> <li>• Nozzle Diameter</li> </ul>	5cm	Provided ✓	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			-NA-
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			-NA-
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			-NA-
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Number of Hydrant per floor</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			-NA-
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>			-NA-
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Auto Starting / Manual Stopping.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			MR
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450LPM	450 LPM ✓	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40m	40m ✓	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided ✓	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided ✓	MR
14.	<b>Captive water storage for firefighting.</b>			-NA-
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Overhead tank capacity.</li> </ul>	10,000 Liter	10,000 liter ✓	MR


N113

15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DFS rules ,the NOC the NOC issued vide letter No. F.6/DFS/MS/School/2016/SZ/1390 dated 08/09/2016, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Mehmood  
 Design: ADO (SJ)

~~DO (SD)~~

*ding*  
24/10

DUFO (SJ)

*ding*  
24/10

~~DO (SJ)~~

*ding*  
28/10

ADO (SJ)

Sir. A. F. T delte put-up for signature/beam

