

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/WZ/2019/ 2114

Dated: 6 / 11 / 2019

FIRE SAFETY CERTIFICATE

Certified that the **J.N. Modern Public School** Located at **WZ-1220, Rani Bagh, Delhi – 110034** comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/MS/DFS/MS/School/2015/WZ/1481, Dated 14/08/2015. The premises was re inspected by the officer concerned of this department on 09/10/2019 in the presence of **Smt. Anita Bhatia (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 – 362 Dated 17-01-2005 and that the premises is fit for occupancy class “Educational” Group B with effect from 6/11/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 6/11/19 at New Delhi by.

(Dharampal Bhardwaj)
DY. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The J.N. Modern Public School Located at WZ-1220, Rani Bagh, Delhi – 110034.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **J.N. Modern Public School, WZ-1220, Rani Bagh, Delhi – 110034.**
2. Type of Occupancy : **Educational (Ground + 2Upper Floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/MS/DFS/MS/School/2015/WZ/1481, Dated 14/08/2015**
5. Fire Safety directives Letter No. : **262-362 Dated-17-01-2005**
6. Date of inspection : **09/10/2019**
7. Name of the Inspecting Officer : **Udaivir Singh, ADO (WP)**
8. Name and designation of Officer
9. from the building side : **Smt. Anita Bhatia (President)**
10. Year of Construction : **1981**
11. Application letter No. : **JNMPS/Fire-S/2019/457 dated 12/09/2019**

| |
|------------------------|
| Area of School- 135sqm |
| Covered Area-74sqm |
| Class rooms-10 |
| Student in School-228 |

| S No | Minimum standards on fire prevention and fire safety U/R 33 | 262-362 Dated-17-01-2005 | Provided at site | Remarks MR/NMR |
|------|--|--------------------------|--|--------------------|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none">• Road width• Gate width• Width of internal road | Accessible | Provided (For small fire unit with one length of hose) | MR(Being old case) |
| | | Accessible | | Provided(On Road) |
| | | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 1 | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1x1.5mtrs | Provided 1x70cm& 1x75cm | MR(Being old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 1 | Provided | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 100cm | Old Case | MR(Being old case) |

| | | | | |
|----|--|-----------------------|----------|----|
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements Syst. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 06 nos. | Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 1 | Provided | MR |
| | • Length of hose reel hose | 30m | Provided | MR |
| | • Nozzle diameter | 5mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10 | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants: | | | |
| | • Size of riser/down-comer | 1 | Provided | MR |
| | • Number of hyd/floor | 1 | Provided | MR |
| | • Hose Box | 1 | Provided | MR |
| 12 | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |

| | | | | |
|-----|--|----------|----------|----|
| 13. | Pumping Arrangements: | | | |
| | <ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 220 lpm | Provided | MR |
| | | 40Mtr | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14. | Captive water Storage for firefighting: | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 5000Ltr | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> ➤ Total area ➤ Location | NA | NA | NA |
| | | NA | NA | NA |
| 19. | Fire control room | | | |
| | <ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|-----|--|----|----|----|

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/MS/DFS/MS/School/2015/WZ/1481, Dated 14/08/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Presently the school is running at Ground & 1st Floor only.

Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ADDO/WP

Signature of the Inspecting Officer

Name

Designation

Dy CPO 11/11/19

ADDO/WZ

19/10/19

ADDO/WP - FT

Six FT letter is put up for sign pk

Dy CPO

11/11/19

MS/Cell

15/10/19