

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2019/ 2829

Dated: 13/11/19

FIRE SAFETY CERTIFICATE

Certified that M/s Kiko Ba & Dadel (A unit of Soul Sunshine Foods LLP), at LGF & GF, 62, Basant Lok, Vasant Vihar, New Delhi-110057, comprised of Ground floor (two level) & three upper floors but restaurant running at ground floor (two level) was issued FSC in the name of M/s **Manchester United Restaurant** (A unit of Twinkle Hospitality Pvt. Ltd) by this department vide letter No. F.6/DFS/MS/EH/2011/1020 dated 30/05/2011. The premise was re-inspected by the officer concerned of this department on 05/11/2019 in the presence of Sh. Uday Pandey (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly, Group-D**" (Restaurant) with effect from 13/11/2019 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/11 /2019 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service
Tel, 011-23414000

Copy to: -

1. Sh. Arjun Jain (Partner), Kiko Ba & Dadel (A unit of Soul Sunshine Foods LLP), LGF & GF, 62, Basant Lok, Vasant Vihar, New Delhi-110057
2. The Dy. Health Officer, South Zone, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi-110003

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	KIKO BA & DADEL (A unit of Soul Sunshine Foods LLP), Commercial Area, LGF & GF, 62, Basant Lok, Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Lower Ground, Ground floor & three upper floors.		
4	Type of Case	Renewal & Change of Name		
5	Details of Previous NOC	F.6/DFS/MS/EH/2011/1020 dated 30/05/2011 in r/o M/s Manchester United Restaurant		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04-04-2005 (N/3)		
7	Date of Inspection	05-11-2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Uday Pandey (Manager)		
10	Year of construction	Restt. at LGF & GF only		
11	Applicant letter No.	Outdoor Diary No. 23616 dated 29-10-2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible -NA- -NA-	6 mtr -NA- -NA-	MR -NA- -NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Lower ground floor. 	-NA- Required	-NA- 2 Nos	-NA- MR
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- Required	-NA- 1.25m (each)	-NA- MR (old case)
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	2 Exits	2m & 1.5m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4	Smoke Management system.			
	<ul style="list-style-type: none"> Lower Ground Floor Ground Floor 	30 ACPH 12 ACPH	Provided Provided	MR MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	8 Nos ABC/W.CO ₂ / CO ₂ ISI marked	10 Nos ABC & CO ₂ Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required Ground floor -NA- Required Required	Smoke type Provided -NA- Provided Near exits	MR MR -NA- MR MR

KIKO BA & DADEL at LGF, LG, 62, Basant Lok, Vasant Vihar, New Delhi-110057

8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	• Lower ground floor	Required	Provided	MR
	• Ground floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	100mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	1200 LPM	1200 LPM /	MR
	➤ Head of main pump.	60m	60m	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	60m	60m	MR
	➤ Standby Pump output.	1200 LPM	1200 LPM	MR
	➤ Standby Pump head.	60m	60m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	15,000 Ltr /	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 Ltr	10,000 Ltr	MR
15	Exit Signage.	Required	Provided /	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided /	MR
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of Special Risk, if any.	2 Nos ABC type fire extinguisher provided near electrical panel		MR


N/ 4

M/s KIKO BA & DADEL (A Unit of Soul Sunshine Foods LLP) at LGF, LG, 62, Basant Lok, Vasant Vihar,
New Delhi-110057

The fire protection system provided in the restaurant premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2011/1020 dated 30/05/2011 in favour of M/s Manchester United Restaurant, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended in favour of M/s Kiko Ba & Dadel (A unit of Sunshine Foods LLP)


Accordingly, DFA is put up for approval and signature please.



Signature of Inspecting Officer
Name: Mehmoed
Design: ADO (SJ)

DO (SD)


09/11

DeFO (S2)


11/11



11/11/15

Adw (S)

PT letter is put up for sign pl

DIRECTOR


(3/11/11)


18/11/19
ADO (Fm)

