GOVERNMENT OF NATION CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2019/SZ/ 2126 Dated: 13/11/19

FIRE SAFETY CERTIFICATE

Certified that the Suraj Bhan DAV Public School located at F-10/15,Vasant Vihar, New Delhi-110057 comprised of basement, ground plus two upper floors owned/occupied by DAV managment was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2016/1510 dated 14/10/2016.. The premises was re-inspected by officer concerned of this department on 25/10/2019 in presence of Mr. Joginder Pal (Admin) and observed that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education circular No.262-232 dated 17/01/2005 issued by Director of Education, Govt. of NCT Delhi and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** subject to conditions mention below.

Issued on 13/11/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, Suraj Bhan DAV Public School, F-10/15,Vasant Vihar, New Delhi-110057.
2. Directorate of Education, G.N.C.T Delhi, Old Secretariat, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/10

LINSPECTION REPORT				
1	Name & Address of the Building	Suraj Bhan DAV Public School,F-10/15,Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Educational, Group–B (School)		
3	Building Comprised of	Basement, Ground Plus Two Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/SZ/2016/1550 dated 14/10/2016.		
6	Fire Safety Directives Letter No	DOE Circular No.262 to 362 Dated 17/01/2005		
7	Date of Inspection	25/10/2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Joginder Pal (Admin.)		
10	Year of construction	1983 & 2002		
11	Applicant letter No.	**SBDAV/Fire Fire Fighting System/G-68/549 dated 02/09/2019**		
S. No	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**As Per Old NOC Requirements**	**Provided at Site (Old Csae-2010)**	**Remarks MR/NMR**
1	**Access to Building.**			
	• Road width	Accessible	9m	MR
	• Gate width	-NA-	3.65,3.64 & 3.46m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	**Number, width, type & arrangement of exits.**			
	a) Number of Staircase			
	➢ Upper floors. ➢ Basement floor.	02 Nos (each block)	02 Nos (each block)	MR
		02 Nos	02 Nos	MR
	b) Width of Staircase			
	➢ Upper floors	1.50m/0.75m	Block 01- 1.44m each Block 02- 1.93m,1.30	MR
	➢ Basement floor	1.50m	1.50m & 1.30m	MR
	c) Protection of exits			
	➢ Fire check door	-NA-	-NA-	-NA-
	➢ Basement	-NA-	-NA-	-NA-
	d) No. of continuous staircase terrace	01no(Each Block)	01no each block	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1mtr	1.10m	MR
3	**Compartmentation.**			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	**Smoke Management system.**			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	**Fire Extinguishers.**			
	• Total numbers	40 Nos	40 Nos	MR
	• Types	ABC/CO2	Provided	MR
	• ISI Marking	ISI mark	Provided	MR

6.	**First Aid Hose Reels.**			
	Total numbers on each floor.	02 nos	03nos at each floor	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR
7	**Automatic fire detection & alarming system.**			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	Required	Provided	MR
10.	**Automatic Sprinkler System**			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• **Sprinkler above false ceiling**	-NA-	-NA-	-NA-
11.	**Internal Hydrants.**			
	• Size of Riser/Down-comer	100mm	Provided	MR
	• Number of Hydrant per floor	01nos	Provided	MR
	• Hose box.	01nos	Provided	MR
12.	**Yard Hydrants.**			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	-NA-	-NA-	-NA-
	➢ Head of main pump.	-NA-	-NA-	-NA-
	➢ Number of main pumps.	-NA-	-NA-	-NA-
	➢ Jockey Pump output.	-NA-	-NA-	-NA-
	➢ Jockey Pump head.	-NA-	-NA-	-NA-
	➢ Standby Pump output.	-NA-	-NA-	-NA-
	➢ Standby Pump head.	-NA-	-NA-	-NA-
	➢ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➢ Pump house access.	-NA-	-NA-	-NA-
	• **Terrace Level**			
	➢ Discharge of pump.	220LPM	900 &180LPM	MR
	➢ Head of pump.	40m Each	46m & 44m	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14.	**Captive water storage for firefighting.**			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➢ Draw-off connection.	-NA-	-NA-	-NA-
	➢ Fire Service Inlet.	-NA-	Provided	-NA-
	➢ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 Liter	25,000 liter	MR
15.	**Exit Signage.**	Required	Provided	MR

N/12

16.	**Provision of Lifts.**			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NR-	-NA-	-NA-
17.	**Standby Power Supply**	-NR-	DG Set	-MR-
18.	**Refuge Area**			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	**Fire Control Room.**			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	**Special Fire Protection System for the Protection of special Risk, if any.**			-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety required under circular Director Of Education dated 17/01/2005, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2016/1580 dated 14/10/2016., renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

DO (SD)

DCFO (SZ)

DELHI FIRE SERVICE
Dy. Chief Fire Officer
1/11/19
307

DO (SD)

ADO (SJ)