

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2019 / 2144

Dated: 14/11/2019

FIRE SAFETY CERTIFICATE

Certified that **Baankura Public School** located at **69, 70, Shri Ganesh Nagar, Burari, Delhi-110084** comprised of **Ground floor** owned/ occupied by **Baankura Public School** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/School/2016/WZ/764 dated 13.05.2016**. The premises was re-inspected by the officer concerned of this department on 11.10.2019 in presence of **Mr. Nakul Sharma (Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from14.11.19..... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on14.11.19..... at New Delhi by.


(Dharmpal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, Baankura Public School, 69, 70, Shri Ganesh Nagar, Burari Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

SPECTION REPORT

1. Name & address of the building : Baankura Public School, 69, 70, Shri Ganesh Nagar, Burari Delhi-110084.
2. Type of Occupancy : Educational
3. Type of Case : Renewal 01 block- (Ground Floor only)
4. Details of previous NOC : F6/DFS/MS/ School /2016/WZ/764 dated 13/05/2016
5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
6. Date of inspection : 11/10/2019
7. Name of the Inspecting Officers : Rajesh Kumar, ADO (RN)
8. Name and designation of officers
from the building side : Mr. Nukul Sharma (Principal)
9. Year of Construction : 2013
10. Applicant's letter No. : BPS/01/2019/2431 Dated 11.09.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	MR
		Accessible	Accessible	NA
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.00 m	MR
	3	Compartmentation.		
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA