

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/BQ/2019/NDZ/ 2138

Dated: 19/11/19

FIRE SAFETY CERTIFICATE

Certified that the Dashmesh Palace Banquet Hall running at First floor only building comprised of ground plus two upper floors (ground floor Reliance Fresh departmental store & second floor vacant) C-35, Main Wazirabad Road, Bhajan Pura, Delhi-110053, owned/occupied by Dashmesh Palace Banquet Hall was issued FSC vide letter no. F6/DFS/MS/2015/NDZ/1896 dated 21/10/15 (for G+1). The premises was inspected by the officer concerned of this department on 30/09/19 in the presence of Mr. Gurmeet Singh (Manager) of the banquet hall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rules 33 Of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class D "Assembly Building" with effect from 19/11/19 for a period of three years, subject to conditions printed overleaf.

Issued on 19/11/19 at New Delhi by

(Atul Garg)
Chief Fire Officer
Delhi Fire Service

To,

The Manager,
Dashmesh Palace Banquet Hall,
C-35, Main Wazirabad Road, Bhajan Pura, Delhi-110053.

Copy to:-

The Dy. Health Officer (EDMC)
SHD(N) Zone, Health Department,
Delhi-110032.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1000/1000

1. Name & address of the building : Dashmesh Palace Banquet Hall, C-35,
Main Wazirabad Road, Bhajan Pura, Delhi-110053
2. Building is comprised of : G+2 Banquet is running at First floor only
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2015/NDZ/1896 dated 21/10/15 (G+1)
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 30/09/19
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer
from the building side : Mr. Gurmeet Singh (Manager)
10. Year of Construction : 2011& 2018
11. Applicant's letter No : Letter No.-Nil, Dated- 19/09/2019


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr. N/A N/A	30 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	02 nos. N/A	02 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	2 m & 1.20 m N/A	2 m & 1.20 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A Required	N/A Ventilated	N/A MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers types IS marking 	12 nos. ABC /CO ₂ ISI marked	12 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 Lpm.	900 Lpm.	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC was issued vide letter no. F6/DFS/MS/2015/NDZ/1896 dated 21/10/15 renewal under the NBC Part-IV, it is recommended.


Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- A.D.O(LN)

Do(ED)


31/11/19
DY CBM


CF/4K
17/10/19

Amu LN

F.T better to put up for sign. please