

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2019/SZ / 2141

Dated: 14/11/19

FIRE SAFETY CERTIFICATE

Certified that the Kenderiya Vidhalaya Located at Sector-5, Dwarka, New Delhi-110075, comprised ground plus three upper floors was issued fire safety certificate vide this department letter no. F6/DFS/MS/School/2016/SZ/1292 dated 17.8.2016 The Said school building was re-inspected by the officer concerned on 24.10.2019 in presence of Sh. Satish Sharma (Principal) & Sh. Ankit Jeenwal (Teacher) and found that the premises have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service 2010, and that the premises is fit for occupancy class B "Educational building" with effect from....14/11/19... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on 14/11/19..... at New Delhi by

  
(Rajesh Panwar)  
Dy.Chief Fire Officer  
Ph.011-26189168  


Copy to:-

1. Asstt. Commissioner, Kendriya Vidhalaya Sangthan, Delhi Region, JNU Camps, New Mehrauli Road, New Delhi-110067.
2. Principal, Kenderiya Vidhalaya ,Sector-5, Dwarka, New Delhi-110075.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

