


**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / School/2019/ 2162

Dated: 15/11 /2019

**FIRE SAFETY CERTIFICATE**

Certified that **M.C Primary Co-Ed. School** located at **Bharola Village, Delhi-110033** comprised of **Ground +01 upper floor** owned/occupied by **M.C Primary Co-Ed. School** have complied with the fire prevention and fire safety requirement in accordance with Director of Education circular issued vide letter no. 3298-3398 dated 01/03/2011 and verified by the officer concerned of this department on 10.03.2017 in presence of **Smt. Padmini Sains Upadhya ( Principal )** and that the building/ premise is fit for occupancy class Group B Educational with effect from .....15.11.19..... for a period of **three years**, subject to compliance of the conditions mentioned below:

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, M.C Primary Co-Ed. School, Bharola Village, Delhi-110033.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : : M.C Primary Co-Ed. School, Bharola Village, Delhi-110033.
2. Type of Occupancy : : Educational
3. Type of Case : : New Case ( G+1 upper Floors)
4. Details of previous NOC : : Nil
5. Fire Safety directives letter No : : Director of Education Circular dated 01.03.2011
6. Date of inspection : : 18.10.2019
7. Name of the Inspecting Officers : : ADO (RN)
8. Name and designation of officers  
from the building side : : Smt. Padmini Sains Upadhya ( Principal )
9. Year of Construction : : 2008
10. Applicant's letter No. : : Nil Diary No. 18161 Dated-27.08.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	MR
		Accessible	Accessible	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
		<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02	02
	b. Width of staircases			
		<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50 m	1.80m & 1.90m
	c. Protection of exits			
		<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size			
		1 m	1.10m each double door	MR
	3	<b>Compartmentation.</b>		
<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> </ul>		NA	NA	NA
		NA	NA	NA

